

November 03, 2016

Michael Anania
NYS School for the Deaf
401 Turin St
Rome, NY 13440

RE: Project: NYSD - BLDG 11A/1st Floor
Pace Project No.: 10366535

Dear Michael Anania:

Enclosed are the analytical results for sample(s) received by the laboratory on October 14, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards andple(s) 3-L4

SAMPLE ANALYTE COUNT

Project: NYSD - BLDG 11A/1st Floor
Pace Project No.: 10366535

| Lab ID | Sample ID | Method | Analysts | Analytes Reported | Laboratory |
|-------------|--------------------------------|-----------|----------|-------------------|------------|
| 10366535001 | Room 1-5/Bathroom | EPA 200.8 | WBS | 1 | PASI-M |
| 10366535002 | Room 1-6/Office | EPA 200.8 | WBS | 1 | PASI-M |
| 10366535003 | Room 1-14/Mens Bathroom | EPA 200.8 | WBS | 1 | PASI-M |
| 10366535004 | Room 1-15/Womens Bathroom | EPA 200.8 | WBS | 1 | PASI-M |
| 10366535005 | Room 1-19/ Lounge | EPA 200.8 | WBS | 1 | PASI-M |
| 10366535006 | Room 1-20/Hallway Fountain | EPA 200.8 | WBS | 1 | PASI-M |
| 10366535007 | Room 1-24/Mens Bathroom | EPA 200.8 | WBS | 1 | PASI-M |
| 10366535008 | Room 1-26/Womens Bathroom/Left | EPA 200.8 | WBS | 1 | PASI-M |
| 10366535009 | Room 1-26/WomensBathroom/Right | EPA 200.8 | WBS | 1 | PASI-M |
| 10366535010 | Room 1-23 | EPA 200.8 | WBS | 1 | PASI-M |

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYSD - BLDG 11A/1st Floor

Pace Project No.: 10366535

Sample: Room 1-5/Bathroom

Parameters

ANALYTICAL RESULTS

Project: NYSD - BLDG 11A/1st Floor

Pace Project No.: 10366535

| Sample: Room 1-24/Mens Bathroom | Lab ID: 10366535007 | Collected: 10/08/16 00:01 | Received: 10/14/16 09:45 | Matrix: Water | | | | |
|---------------------------------|---------------------|---------------------------|--------------------------|---------------|----------|----------|---------|------|
| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

| | | | | | | |
|------|-----|------|------|---|----------------|-----------|
| Lead | 8.0 | ug/L | 0.10 | 1 | 10/21/16 18:03 | 7439-92-1 |
|------|-----|------|------|---|----------------|-----------|

| Sample: Room 1-26/Womens Bathroom/Left | Lab ID: 10366535008 | Collected: 10/08/16 00:01 | Received: 10/14/16 09:45 | Matrix: Water | | | | |
|--|---------------------|---------------------------|--------------------------|---------------|----------|----------|---------|------|
| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

| | | | | | | |
|------|-----|------|------|---|----------------|-----------|
| Lead | 5.4 | ug/L | 0.10 | 1 | 10/21/16 18:04 | 7439-92-1 |
|------|-----|------|------|---|----------------|-----------|

| Sample: Room 1-26/Womens Bathroom/Right | Lab ID: 10366535009 | Collected: 10/08/16 00:02 | Received: 10/14/16 09:45 | Matrix: Water | | | | |
|---|---------------------|---------------------------|--------------------------|---------------|----------|----------|---------|------|
| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

| | | | | | | |
|------|-----|------|------|---|----------------|-----------|
| Lead | 3.2 | ug/L | 0.10 | 1 | 10/21/16 18:05 | 7439-92-1 |
|------|-----|------|------|---|----------------|-----------|

| Sample: Room 1-23 | Lab ID: 10366535010 | Collected: 10/08/16 00:04 | Received: 10/14/16 09:45 | Matrix: Water | | | | |
|-------------------|---------------------|---------------------------|--------------------------|---------------|----------|----------|---------|------|
| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

| | | | | | | |
|------|------|------|------|---|----------------|-----------|
| Lead | 48.8 | ug/L | 0.10 | 1 | 10/21/16 18:06 | 7439-92-1 |
|------|------|------|------|---|----------------|-----------|

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: NYSD - BLDG 11A/1st Floor
 Pace Project No.: 10366535

QC Batch: 442010 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
 Associated Lab Samples: 10366535001, 10366535002, 10366535003, 10366535004, 10366535005, 10366535006, 10366535007,
 10366535008, 10366535009, 10366535010

METHOD BLANK: 2407294 Matrix: Water
 Associated Lab Samples: 10366535001, 10366535002, 10366535003, 10366535004, 10366535005, 10366535006, 10366535007,
 10366535008, 10366535009, 10366535010

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|-----------|-------|--------------|-----------------|----------------|------------|
| Lead | ug/L | ND | 0.10 | 10/21/16 17:48 | |

LABORATORY CONTROL SAMPLE: 2407295

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|-----------|-------|-------------|------------|-----------|--------------|------------|
| Lead | ug/L | 100 | 98.9 | 99 | 85-115 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2411863 2411864

| Parameter | Units | 10366535001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|-----------|-------|--------------------|----------------|-----------------|-----------|------------|----------|-----------|--------------|-----|---------|------|
| Lead | ug/L | 333 | 100 | 100 | 446 | 428 | 114 | 96 | 70-130 | 4 | 20 | |

MATRIX SPIKE SAMPLE: 2411865

| Parameter | Units | 10366538001 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|-----------|-------|--------------------|-------------|-----------|----------|--------------|------------|
| Lead | ug/L | | 1.8 | 100 | 108 | 107 | 70-130 |

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: NYSD - BLDG 11A/1st Floor
Pace Project No.: 10366535

| Lab ID | Sample ID | QC Batch Method | QC Batch | Analytical Method | Analytical Batch |
|-------------|------------------------------------|-----------------|----------|-------------------|------------------|
| 10366535001 | Room 1-5/Bathroom | EPA 200.8 | 442010 | | |
| 10366535002 | Room 1-6/Office | EPA 200.8 | 442010 | | |
| 10366535003 | Room 1-14/Mens Bathroom | EPA 200.8 | 442010 | | |
| 10366535004 | Room 1-15/Womens Bathroom | EPA 200.8 | 442010 | | |
| 10366535005 | Room 1-19/ Lounge | EPA 200.8 | 442010 | | |
| 10366535006 | Room 1-20/Hallway Fountain | EPA 200.8 | 442010 | | |
| 10366535007 | Room 1-24/Mens Bathroom | EPA 200.8 | 442010 | | |
| 10366535008 | Room 1-26/Womens Bathroom/Left | EPA 200.8 | 442010 | | |
| 10366535009 | Room 1- 26/WomensBathroom/Right | EPA 200.8 | 442010 | | |
| 10366535010 | Room 1-23 | EPA 200.8 | 442010 | | |

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,



temp ok

10/19/16